



25th world gas conference
"Gas: Sustaining Future Global Growth"

Combined Heat and Power (CHP)

COGENERATION at PETRONAS' Gas Processing Plant

By: Fairos Roslan, Head of Business Development, PGB

Date: 5 June 2012

Venue: Room 403/404, KL Convention Center



Patron



Host



Host Sponsor



- ❑ To share a case study example of Combined Heat and Power (CHP) on PETRONAS Gas Berhad (PGB)'s Cogeneration Plant installation project at Gas Processing Plant (GPP) A and B Complex, in Terengganu, Malaysia

- **INTRODUCTION TO PETRONAS GAS BERHAD (PGB)**
- **BACKGROUND**
 - Current process operation and utilities at GPP A and GPP B
- **PGB'S PROPOSAL FOR COGENERATION SYSTEM**
 - Process operation and utilities with cogeneration system
- **JUSTIFICATION FOR COGENERATION SYSTEM**
 - Improved reliability of sales gas supply to the country
 - Sales gas saving to the country
 - Energy efficiency
 - Attractive economics
- **CONCLUSION**

Corporate Profile of PETRONAS GAS BERHAD (PGB)

- Private Limited Company
- 23 May 1983
- Public Limited Company
- 28 March 1995



- Listed on KLSE Main Board
- 4 September 1995
- PETRONAS owns 60.63% equity

Business Division of PETRONAS GAS BERHAD (PGB)

MD/CEO

Plant
Operations
Division (POD)



Separating
natural gas into
Sales Gas,
Ethane,
Propane,
Butane &
Stabilised
Condensate

Transmission
Operations
Division (TOD)



Transporting
and distributing
of Sales Gas,
Ethane,
Propane &
Butane via
pipelines

Centralised
Utility
Facilities (CUF)



Producer of
industrial utilities
i.e. Power, Steam,
Nitrogen, Oxygen,
cooling water, etc

Re-Gasification
Terminal
Division
(RGTD)




Operation of the
LNG
Regasification
Facilities and Jetty

Headquarters
(Enablers)



HSE
FINANCE
HRM
COMMERCIAL
PROJECT TEAM
etc



PETRONAS GAS BERHAD (PGB) plays a major role in adding value to Natural Gas



- **INTRODUCTION TO PETRONAS GAS BERHAD (PGB)**
- **BACKGROUND**
 - Current process operation and utilities at GPP A and GPP B
- **PGB'S PROPOSAL FOR COGENERATION SYSTEM**
 - Process operation and utilities with cogeneration system
- **JUSTIFICATION FOR COGENERATION SYSTEM**
 - Improved reliability of sales gas supply to the country
 - Sales gas saving to the country
 - Energy efficiency
 - Attractive economics
- **CONCLUSION**


Current Process Operation and Utilities setup at the Gas Processing Plant (GPP)-A

GPP A



From TNB*
21 MW

Location	Maximum Demand (MW)
GPP 1	4.5
GPP 2	5.5
GPP 3	5.5
GPP 4	5.5
	21



Notes:


* TNB : Tenaga Nasional Berhad i.e. national electricity grid/supplier

Notes:

HRSG : Heat Recovery Steam Generator
IGC : Internal Gas Combustion

Current Process Operation and Utilities setup at the Gas Processing Plant (GPP)-B

GPP B



Notes:

* TNB : Tenaga Nasional Berhad i.e. national electricity grid/supplier

Notes:

HRSG : Heat Recovery Steam Generator


Summary of GPP utilities

UTILITY	SUPPLY CONDITION	DESCRIPTION	CURRENT DEMAND
GPP A			
Electricity	11 kV	Maximum Demand	21,000 kW
		Annual Electricity Consumption	178 million kWh
HP Steam	Pressure: 39.5 bar (abs) Temperature: 390 DegC	Total HP Steam Demand	279 T/hr
		Steam generation from Fired Boilers	78 T/hr
		Steam generation from Waste Heat Boilers	201 T/hr
Fuel Gas	Pressure: 4.5 barg Temperature: 28 degC	Total Consumption	36.6 mmscfd
		Consumption at gas turbines, furnace and other users	27.22 mmscfd
		Consumption at steam system	Supp. Firing at HRSG: 4.23 mmscfd Fired boiler: 5.15 mmscfd
GPP B			
Electricity	132 kV / 33 kV/ 6.6kV	Maximum Demand	22,000 kW
		Annual Electricity Consumption	186 million kWh
HP Steam	Pressure: 44 bar (abs) Temperature: 410 DegC	Total HP Steam Demand	173 T/hr
		Steam generation from Fired Boilers	63 T/hr
		Steam generation from Waste Heat Boilers	110 T/hr
Fuel Gas	Pressure: 4.5 barg Temperature: 28 degC	Total Consumption	31.5 mmscfd
		Consumption at gas turbines, furnace and other users	27.09 mmscfd
		Consumption at steam system	Fired boiler: 4.41 mmscfd

- **INTRODUCTION TO PETRONAS GAS BERHAD (PGB)**
- **BACKGROUND**
 - Current process operation and utilities at GPP A and GPP B
- **PGB'S PROPOSAL FOR COGENERATION SYSTEM**
 - Process operation and utilities with cogeneration system
- **JUSTIFICATION FOR COGENERATION SYSTEM**
 - Improved reliability of sales gas supply to the country
 - Sales gas saving to the country
 - Energy efficiency
 - Attractive economics
- **CONCLUSION**


GPP-A installation of new COGEN unit will enable us to shutdown 2 fired-boilers while satisfying the steam demand

GPP A



GPP-B installation of new COGEN unit will enable us to totally shutdown the operation of fired-boilers

GPP B





Summary of GPP utilities after installation of Cogeneration plant

UTILITY	SUPPLY CONDITION	DESCRIPTION	WITHOUT COGENERATION	WITH COGENERATION
GPP A				
Electricity	11 kV	Maximum Demand	21,000 kW	21,000 kW
		Annual Electricity Consumption	178 million kWh	178 million kWh
HP Steam	Pressure: 39.5 bar (abs) Temperature: 390 DegC	Total HP Steam Demand	279 T/hr	279 T/hr
		Steam generation from Fired Boilers	78 T/hr	40 T/hr
		Steam generation from Waste Heat Boilers	201 T/hr	200 T/hr
Fuel Gas	Pressure: 4.5 barg Temperature: 28 degC	Total Consumption	36.6 mmscfd	39.75 mmscfd
		Consumption at gas turbines, furnace and other users	27.22 mmscfd	27.22 mmscfd
		Consumption at steam system	Supp. Firing at HRSG: 4.23 mmscfd Fired boiler: 5.15 mmscfd	Supp. Firing at HRSG: 4.23 mmscfd Fired boiler: 2.64 mmscfd
		COGEN	-nil-	5.66 mmscfd
GPP B				
Electricity	66 kV	Maximum Demand	22,000 kW	22,000 kW
		Annual Electricity Consumption	186 million kWh	186 million kWh
HP Steam	Pressure: 39.5 bar (abs) Temperature: 390 DegC	Total HP Steam Demand	173 T/hr	173 T/hr
		Steam generation from Fired Boilers	63 T/hr	0 T/hr
		Steam generation from Waste Heat Boilers	110 T/hr	110 T/hr
Fuel Gas	Pressure: 4.5 barg Temperature: 28 degC	Total Consumption	31.5 mmscfd	33.31 mmscfd
		Consumption at gas turbines, furnace and other users	27.09 mmscfd	27.09 mmscfd
		Consumption at steam system	Fired boiler: 4.41 mmscd	Fired boiler: 0 mmscd
		COGEN	-nil-	6.15 mmscfd

- **INTRODUCTION TO PETRONAS GAS BERHAD (PGB)**
- **BACKGROUND**
 - Current process operation and utilities at GPP A and GPP B
- **PGB'S PROPOSAL FOR COGENERATION SYSTEM**
 - Process operation and utilities with cogeneration system
- **JUSTIFICATION FOR COGENERATION SYSTEM**
 - Improved reliability of sales gas supply to the country
 - Sales gas saving to the country
 - Energy efficiency
 - Attractive economics
- **CONCLUSION**

Sales Gas supply reliability to the country will improve from 93.8% to 99.9%





(1) Source data: POD Production Planning department

(2) Source data: Petronas Gas Berhad, Annual Report (2008 – 2010)

(3) Calculated based on GPP

(4) High reliability of power supply to GPP due to parallel operation with TNB. Cogen reliability is at 97.6% as per PGB project proposal

Sales Gas savings to the country is 3.93 mmscfd



Fuel requirement

- TNB
- PGB
- COGEN


Total savings to the country: 3.93 mmscfd

3.93 mmscfd = 19 MW electricity can be generated


3.93 mmscfd = RM 59.5 million/year @ Gas price = RM 38.00/mmbtu

Power generation efficiency comparison between TNB and PGB Cogeneration for GPP-A

INPUT




GPP A Cogen




* Overall TNB Net thermal efficiency was taken from TNB 2010 Annual Report

Power generation efficiency comparison between TNB and PGB Cogeneration for GPP-B

INPUT




OUTPUT




* Overall TNB Net thermal efficiency was taken from TNB 2010 Annual Report

New Cogeneration plant is economically feasible

RM (Million) **COGEN GPP A (Kertih) - Cumulative cashflow**



RM (Million) **COGEN GPP B (Paka) - Cumulative cashflow**



Economics results for 20 years (from Year 2011-2032)

Item	Cost (RM)
ROI	17.8 %
NPV@ 10%	RM 71.9 million
Payback period	6.5 years

Item	Cost (RM)
ROI	26.7%
NPV@ 10%	RM 147.6 million
Payback period	3.5 years

- **INTRODUCTION TO PETRONAS GAS BERHAD (PGB)**
- **BACKGROUND**
 - Current process operation and utilities at GPP A and GPP B
- **PGB'S PROPOSAL FOR COGENERATION SYSTEM**
 - Process operation and utilities with cogeneration system
- **JUSTIFICATION FOR COGENERATION SYSTEM**
 - Improved reliability of sales gas supply to the country
 - Sales gas saving to the country
 - Energy efficiency
 - Attractive economics
- **CONCLUSION**

This COGENERATION Project will benefit the country in the aspect of...



- **Transfer of operational risk from TNB to PGB** for the security of supply for sales gas to the country
- **Improved reliability of sales gas supply** to the nation from 93.8% to 99.9%, above world class reliability standard.
- **Net reduction of sales gas volume** available to the nation by 3.93 mmscfd
- **Improved overall thermal efficiency** from 39.4% to 69% at GPP A and 71% at GPP B.
- **Economically feasible** with Internal Rate of Return (IRR) of 17.8% and 26.7% at GPP A and GPP B respectively.



Thank You

optimize
save **more.earnmore**

GPTA₄

BACKUP SLIDES

Calculation

Upstream reliability = $\frac{\text{Actual supplied volume}}{\text{Plant capacity}}$

2007

$$\frac{2321}{2512} = 92.4\%$$

2010

$$\frac{1972}{2512} = 78.5\%$$

2014

$$\frac{2437}{2512} = 97.0\%$$

* Calculated based on KPBI yr 2014

* Figures are calculated based on actual data

2015

$$\frac{2470}{2512} = 98.3\%$$


Power supply reliability to GPP (based on 4 years data)

Year	GPP A Outage (hr)	GPP B Outage (hr)	GPP A Reliability (%)	GPP B Reliability (%)
2010	1.2	0	99.99	100
2009	0	0	100	100
2008	48.25	0	99.45	100
2007	0	0	100	100


Power generation thermal efficiency (extracted from TNB 2010 Annual Report, pg 121)



Graph 14: Trending of TNB Thermal Efficiency (%)



Graph 13: Thermal Efficiency by Station (%)




Economic assumptions (1/2)

NO	DESCRIPTION	INFO / VALUE ASSUMPTIONS
1	Maximum Demand During Peak Period	GPP A : 21 MW , GPP B : 22 MW
2	Total power consumption	GPP A : 178 Mil kWh , GPP B : 186 kWh
3	Natural Gas Price	RM 10.70/ mmbtu according to GPTA until 2014. By the year 2015 onwards, RM 38/mmbtu as per PEMANDU guideline
4	Total CAPEX Cost	RM 142.6 mil (per GPP)
5	Project Life	20 Years. Commercial Operation Date (COD) -July 2013
6	Debt : Equity Ratio	100 % Equity
7	Depreciation	Straight line over 20 years
8	Capital Allowance	1 st Yr: 34%, 2 nd -5 th Yr: 14%,6 th Yr: 10%
9	Reinvestment Allowance	60 %
10	Corporate Income Tax	25 %
11	TNB Electric Tariff Charge	GPP A : E2 Rate, GPP B : E3 Rate
12	TNB Electricity Annual Increment	3.0% (Based on historical data)
13	Non Firm Stand-by From TNB	GPP A: 9 MW, GPP B : 10 MW

Economic assumptions (2/2)


NO	DESCRIPTION	INFO /VALUE ASSUMPTIONS
14	Discount Rate	10%
15	Exchange Rate	1 USD = RM 3.03 as publish by Bank Negara Malaysia on the 22 nd Feb 2011
16	GT ,Generator & HRSG Maint	RM 2.3 Million /yr
17	Annual Increment of Gas Turbines & Generator Maintenance Cost	3 % (Based on average US-CPI index)
18	GTG and HRSG Reliability	96%

Existing GPP-A Steam System Overview (GPP Generates 78 t/hr of steam from fired-boilers)




GPP-A Steam System Overview – Post COGEN project i.e. able to shutdown 4/6 fired-boilers

Figure B : GPP A Steam production and distribution with COGEN



Existing GPP-B Steam System Overview (GPP Generates 63 t/hr of steam from fired-boilers)



GPP-B Steam System Overview – Post COGEN project i.e. able to shutdown ALL fired-boilers

