

25th world gas conference  
“Gas: Sustaining Future Global Growth”

# Effects of the Large-scale Earthquake and Tsunami on an LNG Receiving Terminal

Nobuhiko Takei,  
The Japan Gas Association  
6th JUN 2012



Patron



Host



Host Sponsor




- ◆ Damage to an LNG receiving terminal
- ◆ Procedure of emergency recovery
- ◆ Measures for restoration

- 1. Summary of “ The Great Eastern Japan Earthquake”**
2. Damage to the LNG Receiving Terminal
3. Procedure of Emergency Recovery
4. Measures for Restoration
5. Conclusion


# 1-1. Summary of “ The Great East Japan Earthquake”

Date and Time	14:46, JST 11th of March, 2011
Magnitude	Mw 9.0
Hypocenter	130km ESE off coast, Depth 24km
Characteristic	<ul style="list-style-type: none"> <li>▪ The biggest earthquake in the modern history of Japan.</li> <li>▪ The duration of the earthquake was long as 170 seconds.</li> <li>▪ The seismic area was 200km in width and 500km in length.</li> </ul>



# 1-2. Reported Height of Tsunami


- The height of the tsunami was unprecedented in modern times.
- The maximum flood height was 15 meters with a run up height of 40 meters.




1. Summary of “ The Great Eastern Japan Earthquake”
- 2. Damage to the LNG Receiving Terminal**
3. Procedure of Emergency Recovery
4. Measures for Restoration
5. Conclusion

# 2-1. Outline of the Minato LNG Receiving Terminal, The Gas Bureau of Sendai City

■ The gas supply process comprises an LNG re-gasification system and a natural gas high-pressure pipeline system from inland.



\*1 Calorie valve adjustment equipment.





HP-NG pipeline

- < Ratio of gas sendout volume >
- LNG re-gasification system : 7
  - NG high-pressure system : 3

High-pressure natural gas pipeline

## 2-2. Damage to the LNG Receiving Terminal

- Earthquake caused almost no damage.
- Tsunami (maximum 4 meters height from the ground) struck 1 hour after the earthquake.
- The operationability of LNG terminal was lost, however there was no loss of life, LNG leaks, or any other secondary disasters.



## 2-2. Damage to the LNG Receiving Terminal

video

## 2-3. Damage by the Tsunami

- All areas except LNG tank area were flooded.
- Soil of 2 meters from the ground was scoured.




Photo : Geographical Survey Institute on the next day of the earthquake

# 2-3. Damage by the Tsunami

## -Characteristics of Damage by the Tsunami



Near the sea water sluice gate



### Damage of washed away areas

- The area where flow was concentrated was seriously damaged.
- Drifting objects didn't cause serious damage.
- The slab foundation was damaged.
- Equipment with pile foundations were not seriously damaged.
- Erosion was quick to occur around unpaved locations.



Flat slab foundation structures



Water tank (pile foundation)

## 2-4. Damage of equipment —LNG receiving facilities—



### ◆ 1. Receiving Equipment

Only some scouring on the surface of the ground which did not effect it's operationability.




### ◆ 2. Bank

There was some partial scouring on the surface. However, there was no damage to the sheet-pile and the bank remained intact.




## 2-4. Damage of equipment —LNG & LPG storage tanks—



### ◆ 2. LPG storage tank

A part of it was flooded, some of the soil around the foundation was washed away, but there was no damage.



### ◆ 1. LNG inground tank

Luckily being on the top of a 4 meter banking hill spared it from being flooded.



## 2-4. Damage of equipment –LNG piping and piping framework–

### ◆ 1. Shallow foundation of piping framework

- Framework collapsed due to being washed away around the foundation which were quite shallow.
- Although the piping was deformed there were no LNG leaks.



Damage



## 2-4. Damage of equipment —LNG piping and piping framework—




### ◆ 2. Loosely fitted piping allowed floating

- End of branch piping for future additional piping was not completely fixed to any framework and as such suffered severe deformation.
- Emergency shut down was carried out quickly, and there were no LNG leaks.



## 2-4. Damage of equipment —Piping and piping framework—



- ◆ 1, 2 The piping frame of the pile foundation and underground piping

Although these were suffered severe water flooding, there was no damage and the operationability was maintained.

- ◆ 1. Gas distribution pipe




No damage

- ◆ 2. Piping over pile foundation



## 2-4. Damage of equipment —LNG Vaporizer—




- ◆ 1. Open rack vaporizer  
It was not damaged.

No damage




- ◆ 2. Submerged combustion vaporizer  
Control board and combustion air blower were flooded and the operationability was lost.



Damage

## 2-4. Damage of equipment —Electric/Control System Equipment—



### ◆ 1. Substation equipment

Tsunami damaged non watertight doors allowing internal flooding.

The equipment operations failed.



Damage

### ◆ 2. Power receiving equipment

Outside installation was flooded and equipment failed.



Damage



## 2-4. Damage of equipment —other equipment—



### ◆ 2. BOG compressor

It was installed on the second floor and not damaged.



### ◆ 1. Odorization equipment

It had highly airtight doors with no aperture, no flooding occurred.



## 2-4. Damage of equipment —buildings—



- ◆ 2. LNG truck loading building  
A lightweight building was swept away.



Damage

- ◆ 1. Berth control center building  
The wall and windows at the first floor were damaged.



Damage


## 2-5. Summary of damage to the LNG Receiving Terminal

- The main cause of the damage to the facilities was the tsunami.
- Gas outage due to the shut down of the Electric and Control system equipment.
- There was no loss of life , LNG leaks , or any other secondary disasters.

1. Summary of “ The Great Eastern Japan Earthquake”
2. Damage to the LNG Receiving Terminal
- 3. Procedure of Emergency Recovery**
4. Measures for Restoration
5. Conclusion

### 3. Procedure of Emergency Recovery

- The complete recovery of the plant was assumed to take a substantial amount of time.
- A high-pressure natural gas pipeline from another terminal was utilized for the early restoration (emergency restoration) of the gas supply.
- Safety measures and the implementation of emergency measures for the minimum necessary requirements to monitor the plant.
- Resumption of the gas supply took place 12 days after the earthquake and the tsunami.



1. Summary of “ The Great Eastern Japan Earthquake”
2. Damage to the LNG Receiving Terminal
3. Procedure of Emergency Recovery
- 4. Measures for Restoration**
5. Conclusion


## 4-1. Measures for Restoration

### -Basic Approach to Tsunami Countermeasures for restoration -

- 1) Take into account the actual tsunami height for design
- 2) Arrange certain safety measures to protect human life
- 3) Improve resistance to tsunami on important facilities that impact early restoration

## 4-2. Restoration Schedule

■ It has taken a total of 12 months from the earthquake for full recovery of LNG re-gasification equipment.



# 4-3. Measures to improve facilities

## -Preventing Piping and Piping Framework from being damaged-

■ The foundation of piping framework was changed from slab type to pile type.



Secure pipes to prevent floating

a slab foundation

a pile foundation

# 4-3. Measures to improve facilities

## -Improved Building Flood Prevention-

- Replacing doors of important buildings with watertight (airtight) doors like those in the odorization building.



## 4-3. Measures to improve facilities -Improved Building Flood Prevention-

- Apertures of the building were moved to higher locations.



The Air compressor building

- The LNG receipt and truck loading monitoring facilities, which had been on the first floor and suffered damage, were relocated to the second floor.

1. Summary of “ The Great Eastern Japan Earthquake”
2. Damage to the LNG Receiving Terminal
3. Procedure of Emergency Recovery
4. Measures for Restoration
- 5. Conclusion**

# 5. Conclusion

## Damage Situation

- Earthquake and Tsunami scale were the largest in modern times.
- Gas outage due to serious damage to Electric/control system and other equipment.

## Observation

- The earthquake barely affected the plant's operationability.
- The main cause of damage to the facilities was the Tsunami.

## Countermeasure

- It is difficult to completely protect facilities from tsunamis of this size.
- To achieve early recovery, it is necessary to improve the tsunami resistance of equipment that takes a long time to repair.
- For example, making buildings more water-tight, raising equipment above expected flood levels and changing to pile foundations.

Our report should provide a useful reference for future tsunami countermeasures at LNG terminals worldwide.

Thank you for your attention